



iWATER

KNOWLEDGE TO ENVIRONMENTAL SOLUTIONS

# WATER MONITORING REPORT

## Renergen: Storm Water Dam

---

Kabelo Duiker | 067 104 4289 | [Kabelo@renergen.co.za](mailto:Kabelo@renergen.co.za)

Esta van Heerden (Ph.D.) | 082 374 2855 | [Esta@iwatersolutions.co.za](mailto:Esta@iwatersolutions.co.za)

Dr Marieta Cawood (Ph.D.) | 083 262 2944 | [Tech2@iwatersolutions.co.za](mailto:Tech2@iwatersolutions.co.za)

June 2024

# DOCUMENT ISSUE STATUS

|                         |                         |
|-------------------------|-------------------------|
| Report Issue            | 1                       |
| Report Reference Number | 2024.149                |
| Report Title            | Water Monitoring Report |
| Report Date             | June 2024               |

| iWater Sign-off        | Name                   | Signature   | Date         |
|------------------------|------------------------|---|--------------|
| Compiled by            | Marieta Cawood         |    | 27 June 2024 |
| Edited and verified by | Marieta Cawood         |    | 27 June 2024 |
|                        | Prof. Esta van Heerden |    |              |
| Approved by CEO        | Prof. Esta van Heerden |  | 27 June 2024 |

## DISCLAIMER

THE CLIENT UNDERTAKES NOT TO UTILISE ANY CONFIDENTIAL INFORMATION FOR ADVISING, ASSISTING, AND ENGAGING WITH THIRD PARTIES USING THIS REPORT. THIS REPORT IN NO WAY SHOULD BE USED AS FACTUAL REFERENCE AND THIS REPORT ALSO DOES NOT MEAN THAT IWATER (PTY) LTD. IS IN ANY WAY ENDORSING SPECIFIC PRODUCTS OR SERVICES. FURTHERMORE, THE RECIPIENT UNDERTAKES NOT TO USE THIS INFORMATION AND BY DOING SO WHETHER DIRECTLY OR INDIRECTLY, ENGAGE IN ANY BUSINESS WHICH COMPETES OR INTENDS TO COMPETE WITH IWATER (PTY) LTD. ALL INFORMATION IN THIS DOCUMENT IS DEFINED AS CONFIDENTIAL.

# TABLE OF CONTENTS

---

|           |  |          |
|-----------|--|----------|
| <b>1.</b> | <b>Introduction .....</b>                            | <b>4</b> |
| <b>2.</b> | <b>Sampling .....</b>                                | <b>4</b> |
| <b>3.</b> | <b>Results .....</b>                                 | <b>5</b> |
| 3.1       | Microbial  | 5        |
| 3.2       | Chemical   | 5        |
| <b>4.</b> | <b>Treatment Options .....</b>                       | <b>7</b> |
| Table 1:  | Microbial results for the SWD water sample June 2024 | 5        |
| Table 2:  | Chemical results of SWD water sample June 2024.      | 5        |

# 1. INTRODUCTION

---

iWater has recognized the need for directing the **specific analyses** selected, followed by accurate analysis to support clients to achieve compliance in their environmental management strategies. We offer a selection of quality tests for any type of environmental or waste sample. We do not select standard packages but use expert advice to support the client to decide on the most appropriate tests to create a comprehensive understanding of the site compliance. **iWater operates its in-house laboratory and development centre, but data is also independently verified with aligned SANAS accredited partners.**

iWater's qualified and expert staff is always available to assist any client to understand chemical and microbial results, while our knowledge, as well as international experts, are geared to remedy any situation. Monitoring is only a tool to support effective resource management, therefore iWater is a leader in supplying innovative sustainable solutions for water and soil remediation.

# 2. SAMPLING

---

iWater received water samples from Mr Kabelo Duiker from Renergen on the 10<sup>th</sup> of June 2024. The water sample was collected from the storm water dam (SWD) on site. The sample was analysed by an independent SANAS laboratory within 48 hours. Data is discussed below.

The aim is to determine if the water sample complies with the wastewater limits as stipulated in the GA standards as given by the National Water Act 1998 (ACT No. 36 of 1998).

## 3. RESULTS

### 3.1 Microbial

**Table 1: Microbial results for the SWD water sample June 2024**

| Determinant      | Units      | SANS 241:(2015) Limits | 2013 GN 665 GA | Risk <sup>1</sup>  | SWD June |
|------------------|------------|------------------------|----------------|--------------------|----------|
| Faecal coliforms | cfu/100 ml | 10                     | 1000           | Operational        | <1       |
| <i>E. coli</i>   | cfu/100 ml | 0                      |                | Acute Health Micro | <1       |

There were no faecal coliforms or *E. coli* bacteria detected in the SWD water sample and the water complies to SANS 241: (2015) standards for drinking water as well as GA standards for wastewater.

### 3.2 Chemical

**Table 2: Chemical results of SWD water sample June 2024.**

| Determinants                 | Units                   | 2013 GN 665 Limits <sup>1</sup> | SWD June |
|------------------------------|-------------------------|---------------------------------|----------|
| Alkalinity                   | mg CaCO <sub>3</sub> /L |                                 | 162      |
| Electrical conductivity (EC) | mS/m                    | <200                            | 56.6     |
| pH                           | pH units                | 5.0 – 9.0                       | 7.91     |
| Total Hardness               | mg/L                    |                                 | 130      |
| Total Suspended Solids (TSS) | mg/L                    | <25                             | 47.2     |
| Total Dissolved Solids (TDS) | mg/L                    |                                 | 323      |
| Turbidity                    | NTU                     |                                 | 34.0     |
| Chemical Oxygen Demand (COD) | mg/L                    | <75                             | 72.0     |
| Chlorine (Free)              | mg/L                    | <0.25                           | <0.1     |
| Ammonia                      | mg/L                    | <6                              | 0.64     |
| Calcium as Ca                | mg/L                    |                                 | 25.8     |
| Chloride as Cl               | mg/L                    |                                 | 50.2     |

|                             |      |        |             |
|-----------------------------|------|--------|-------------|
| Fluoride as F               | mg/L | <1     | 0.63        |
| Soap, oil and grease        | mg/L | <2.5   | 1.6         |
| Magnesium as Mg             | mg/L |        | 16.0        |
| Nitrate as N                | mg/L | <15    | <0.35       |
| Nitrite                     | mg/L |        | <0.01       |
| Ortho Phosphate             | mg/L | <10    | <0.03       |
| Potassium as K              | mg/L |        | 16.5        |
| Sodium as Na                | mg/L |        | 58.3        |
| Silicon as Si               | mg/L |        | 0.13        |
| Sulphate as SO <sub>4</sub> | mg/L |        | 57.4        |
| Aluminium as Al             | mg/L |        | 0.12        |
| Antimony as Sb              | mg/L |        | <0.01       |
| Arsenic as As               | mg/L | <0.02  | <0.009      |
| Boron as Bo                 | mg/L | <1     | 0.02        |
| Cadmium as Cd               | mg/L | <0.005 | <0.002      |
| Chromium as Cr              | mg/L | <0.05  | <0.01       |
| Cobalt as Co                | mg/L |        | <0.01       |
| Copper as Cu                | mg/L | <0.01  | <0.01       |
| Cyanide (Free)              | mg/L | <0.02  | <0.01       |
| Total iron (acid treated)   | mg/L |        | 0.50        |
| Iron as Fe                  | mg/L | <0.3   | 0.10        |
| Lead as Pb                  | mg/L | <0.01  | <0.01       |
| Manganese as Mn             | mg/L | <0.1   | <0.01       |
| Mercury as Hg               | mg/L | <0.005 | <0.003      |
| Nickel as Ni                | mg/L |        | <0.01       |
| Selenium as Se              | mg/L | <0.02  | <0.02       |
| Zinc as Zn                  | mg/L | <0.1   | <0.01       |
| Total Organic Carbon (TOC)  | mg/L |        | <b>25.6</b> |

The chemical data indicated elevated levels of total suspended solids in the storm water dam sample and the value exceed the limits of GA standards as given by the National Water Act 1998 (ACT No. 36 of 1998).

The high suspended solids and TOC are likely to decrease dissolved oxygen levels in the water which can negatively affect aquatic health when water is released into the environment.

## 4. TREATMENT OPTIONS

---

A silica sand filter is a widely used filtration device that removes suspended particles from water by passing it through a bed of silica sand. This process is common in water treatment and industrial applications due to its simplicity and effectiveness. The filtration process begins with the introduction of feed water into the filter tank, where it is evenly distributed across the surface of the silica sand bed to ensure uniform filtration. As the water percolates through the layers of silica sand, suspended particles, debris, and impurities are trapped in the sand bed through physical straining and adsorption. The filtered water, free of suspended solids, is then collected at the bottom of the filter and directed to the clean water outlet.

However, there are also some drawbacks to silica sand filters. They require frequent maintenance, including regular backwashing, and are not effective in removing very fine particles, dissolved substances without additional treatment. Usually before selecting the matrix sizes a particle size distribution analysis is done to select the most appropriate matrix. The backwashing process generates wastewater that needs to be managed and treated, and over time, the sand may need to be replaced or replenished, adding to maintenance costs. Despite these limitations, silica sand filters remain a reliable and cost-effective solution for water filtration, providing effective removal of suspended solids and improving water quality for various applications.

Alternatively, a Granular Activated Carbon (GAC) filter can be installed, especially if a large portion of TSS is organic matter. GAC is a highly porous adsorption media commonly used in water treatment to remove organic contaminants, chlorine, odours, and other impurities. GAC is widely used in drinking water purification, wastewater treatment, and industrial processes due to its high efficiency in removing a wide range of pollutants and improving water quality.

Contact time and vessel size is a process engineering principle for efficient filtration.

**Please feel free to engage with us if you have any questions.**

***This report only reflects the analysis and safety for the batch water source of the supplied water samples.***