



**Sedibeng
WATER**

Private Bag X1, Delportshoop, 8377

(nat.) 053 562 9300
(intl.) +27 53 562 9300

(nat.) 053 562 9330
(intl.) +27 53 562 9330

www.sedibengwater.co.za
ceosec@sedibengwater.co.za



Winner of
Century Quality
International
ERA Award

**Ref. P3
FAB/fb**

DATE: 24 JUNE 2019

**TETRA 4
1 BOMPAS ROAD
DUNKELD WEST
JOHANNESBURG
2196**

ATTENTION: Mr. DLAKAVU

THEUNISSEN GASIFICATION PROJECT: WATER SUPPLY

Dear Sir,

Your application for a new water draw off from the existing Sedibeng Water's Oryx pipe line refers.

Currently Sedibeng Water has a 400 mm diameter pipe line up to point L on your drawing submitted. Currently the specific pipe line is supplying water to Oryx gold mine. The current water consumption of the mine shows that the pipe line has spare capacity to supply your anticipated 52 cubic metres per hour demand. Sedibeng Water confirms herewith that your application is approved; provided that the installation cost as well as the deposit is paid by yourselves. The installation costs will be forwarded to you in due course.

The pipe line is supplied from Sedibeng Water's Leeuwbult reservoirs nearby with a ground level of 1416, 28. The level at your proposed draw off position is 1343, 00, which gives a static pressure of 73, 28 m.

We hope that you will find the above in order. If you need any more information, you are welcome to contact Mr. Gideon Dippenaar from this office. He can be reached on 0836303075.

Yours faithfully,

**MR. M. MOKUBUNG
ACTING CHIEF OPERATIONS OFFICER**

