



TIP LOAD = 23 kN

DESIGN REQUIREMENTS			C A H (m AGL)			
POLE LENGTH L	TIP LOAD (kN)	PLANTING DEPTH P	E	T	M	B
20	23	2.6	17.4	15.2	14.1	13.0
21	23	2.7	18.3	16.1	15.0	13.9
22	23	2.8	19.2	17.0	15.9	14.8
23	23	2.9	20.1	17.9	16.8	15.7
24	23	3.0	21.0	18.8	17.7	16.6

2	DRG SHT UPDATED. REFERENCES REV'D. GENERAL REVISION	SLR	RAB	AB	JUNE 2004	
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.

<p>Eskom Distribution</p> <p>AUTH: A BEKKER</p> <p>DATE: JAN 2004</p> <p>CHKD: RAB</p> <p>DATE: JAN 2004</p> <p>DRAWN: LMP</p> <p>DATE: NOV 1998</p>	<h2>DISTRIBUTION TECHNOLOGY</h2> <h3>RETICULATION/SUB-TRANSMISSION LINES</h3> <h3>88/132KV S/C INTERMEDIATE STRUCTURE</h3> <h3>GENERAL ARRANGEMENT</h3>								
	D-DT 7611		<table border="1"> <tr> <th>SET</th> <th>SHEET</th> <th>REVISION</th> </tr> <tr> <td style="text-align: center; font-size: 2em;">2</td> <td style="text-align: center; font-size: 2em;">1</td> <td style="text-align: center; font-size: 2em;">2</td> </tr> </table>	SET	SHEET	REVISION	2	1	2
	SET	SHEET	REVISION						
	2	1	2						

